



Aalborg Universitet

AALBORG UNIVERSITY  
DENMARK

## Nonlinear Coss-VDS Profile based ZVS Range Calculation for Dual Active Bridge Converters

Liu, Bochen; Davari, Pooya; Blaabjerg, Frede

*Published in:*  
IEEE Transactions on Power Electronics

*DOI (link to publication from Publisher):*  
[10.1109/TPEL.2020.3003248](https://doi.org/10.1109/TPEL.2020.3003248)

*Publication date:*  
2021

*Document Version*  
Accepted author manuscript, peer reviewed version

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*  
Liu, B., Davari, P., & Blaabjerg, F. (2021). Nonlinear Coss-VDS Profile based ZVS Range Calculation for Dual Active Bridge Converters. *IEEE Transactions on Power Electronics*, 36(1), 45-50. [9119872].  
<https://doi.org/10.1109/TPEL.2020.3003248>

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

### Take down policy

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# Nonlinear $C_{oss}$ - $V_{DS}$ Profile based ZVS Range Calculation for Dual Active Bridge Converters

Bochen Liu, *Student Member, IEEE*, Pooya Davari, *Senior Member, IEEE*, Frede Blaabjerg, *Fellow, IEEE*

**Abstract**—Generally, power electronic converters are designed to obtain the highest efficiency at rated power while they are most often operated under partial loading conditions. For dual active bridge (DAB) converters, the zero-voltage-switching (ZVS) conditions can be impaired under light load situations. While load depending ZVS operation has been introduced by prior-art approaches, the nonlinear characteristic of the output capacitance in a power device is often not considered and its effect on operating boundaries of ZVS is neglected. In this letter, based on practical switching transients, an improved method of calculating the ZVS range is introduced. By taking into account the non-linearity of output capacitance, the method is developed from a detailed analysis of real switching transients. A 2.5 kW prototype is built, and a comprehensive comparison with prior-art approaches is conducted to validate the accuracy of the proposed method.

## I. INTRODUCTION

One advantage of the DAB converter [1] is the inherent capability of naturally achieving ZVS for all switches without any auxiliary circuits, and this advantage has facilitated a wide application of DAB converters, such as in distributed power systems [2], energy storage systems [3] and electric vehicles [4]. However, due to the lower leakage inductance current in light-load conditions, the charge stored in the transistor output capacitor may not be totally released during the dead time, and this might result in ZVS failure owing to high voltage across the transistor at the turn-on instant. This failure would further increase the switching losses, impair the electromagnetic compatibility (EMC) performance [5] and even damage the power devices [6].

There are two commonly used methods to identify the limitations on the control variables for achieving ZVS, i.e. current-based method [7], [8] and energy-based method [9]. Therein, the current-based method is developed from the body diode conduction when the power device is switched on and thus ZVS conditions can be attained by controlling a positive or negative leakage inductance current at the switching instants. However, the positive/negative current direction is the result of the ZVS achievement, which is not sufficient to guarantee a soft switching. In respect to the energy-based method, the ZVS is achieved under the condition that the energy stored in the output capacitance  $C_{oss}$  is totally released before the transistor is switched on. This method is better by requiring a minimum leakage inductance current at the switching instants. However, the non-linearity of the parasitic output capacitance is usually not taken into account, in spite of the fact that the output capacitance of a power device varies a lot during the turn-on/turn-off procedure. Besides, the calculation procedure is complex regarding the square mathematical operation of

the stored energy (e.g.  $1/2Li^2$ ). Moreover, due to that more converter components are involved in the calculation, a high modeling accuracy of the involved components (e.g. the transformer) is required for an accurate ZVS range calculation and this accurate modeling would further increase the complexity. Consequently, owing to the missing consideration of the non-linearity and the complex calculation procedure, the obtained ZVS range using the method would contain some critical operating points that could lead to ZVS failure.

A charge-based ZVS calculation method is proposed in [10], where the nonlinear change of output capacitance is involved. This method can achieve a more accurate ZVS operating range, and thus this letter also calculates the ZVS range based on the charge balance. But compared to the method in [10], the main difference and improvements of the proposed method in this letter are listed in the following.

Firstly, the calculation of the available charges in [10] is not appropriate. In [10], the integration of the bridge current starts from the zero-crossing time instants to the switching moment, and the results are compared with the required discharge of the output capacitance. However, the time range between the two zero-crossing instants [10] might not be the discharging time interval of the output capacitance. In practical switching transients (cf. Section II), the actual integration limits should start from the instant when the drain-source voltage begin to reduce, and end at the instant when the drain-source voltage becomes zero. The whole discharging interval is within this starting point and ending point, during which the discharge of the output capacitance synchronizes with the charge movement in the bridge current. Hence, this discharging interval is the proper integration interval for calculating the conveyed charges by the bridge current. Actually, this discharging interval is equal to the dead time, and it is not involved in the charge calculation in [10]. More details can be found in Section IV.

Secondly, the half dc-bus voltage change consideration in [10] is not appropriate because the drain-source voltage of a power device will switch between zero and the whole dc-bus voltage during transients. The turn-on of one power device corresponds to the turn-off of the other one at the same time. Therefore, the charge and discharge of the power devices in the same bridge leg are analyzed together (Section III) in this paper.

In this letter, a nonlinear  $C_{oss}$  profile based ZVS range calculation method is presented according to practical switching transients in a DAB converter. Notably, this method can be applied to the full load range, but due to that the DAB is easier to lose ZVS in light load, this letter will focus on light-load operation. The measured switching transients are




Fig. 1. Circuit topology of a DAB converter with full-bridges  $FB_1$  and  $FB_2$ .




Fig. 2. Operation of the DAB converter (a) Typical operation mode characterized by  $\alpha_p$ ,  $\alpha_s$  and  $\varphi$ . (b) General MOSFET model and resultant circuit state of the full-bridge  $FB_1$  during the turn-on of  $Q_4$ .




Fig. 3. A detailed description of the three control variables  $\alpha_p$ ,  $\alpha_s$  and  $\varphi$  in practical control.

firstly shown in Section II. Then ZVS analysis concerning the nonlinear change of the output capacitance is conducted in Section III. Next, a comparative analysis with other ZVS calculation methods is presented and verified by experimental results in Section IV, including a comparison with the charge-based method proposed in [10]. At the end, the conclusions are summarized.

## II. PRACTICAL SWITCHING TRANSIENTS

A DAB converter topology is shown in Fig. 1. It mainly consists of two full-bridges (i.e.  $FB_1$  and  $FB_2$ ) generating a two-level or three-level ac voltage (i.e.  $v_p$  and  $v_s$ ) across the transformer-inductor combination. A generalized light-load modulation method [11] is applied and relevant working waveforms are as shown in Fig. 2(a). Therein, three control variables are used to regulate the converter, i.e. duty cycles ( $\alpha_p$ ,  $\alpha_s$ ) of  $v_p$ ,  $v_s$  and the phase shift angle ( $\varphi$ ) between the

TABLE I  
SYSTEM PARAMETERS OF A DAB PROTOTYPE

Parameter	Variable	Value
Input DC voltage	$V_1$	200 V
Output DC voltage	$V_2$	35 V
Turns ratio of the transformer	$n : 1$	3.5 : 1
Switching frequency	$f_{sw}$	60 kHz
Leakage inductance	$L$	45 $\mu$ H




Fig. 4. Measured transient drain-source voltages and gate-source voltages of  $Q_4$  at turning on. Control parameters:  $\alpha_p = 60^\circ$ ,  $\alpha_s = 110^\circ$ , and  $\varphi = 3^\circ, 4^\circ, 5^\circ \dots 10^\circ$  in the 8 cases, respectively.

fundamental components of these two voltages. It is common that a dead time  $T_{dead}$  is inserted between the two power devices in the same leg (e.g.  $Q_2$  and  $Q_4$ ) to avoid short circuit. As a result, this might cause  $\varphi$  to drift in practical control, and hence the dead time effect on the control variables should be considered and properly compensated [12], [13]. In this paper, by using the dead time compensation methods in [12], the practical control variables are depicted in details as shown in Fig. 3.

As highlighted in Fig. 2(a), the power device  $Q_4$  is turned on at  $t = t_3$ , and meanwhile,  $Q_2$  is turned off and  $Q_1$  is kept on. Consequently, the transient turning on procedure of  $Q_4$  can be described by the  $FB_1$  transition circuit in Fig. 2(b). In a MOSFET device, parasitic capacitances are coupled among the drain, source and gate terminals, denoted by  $C_{GD}$ ,  $C_{GS}$  and  $C_{DS}$  in Fig. 2(b). On this basis, a nonlinear characteristic defined by  $C_{oss} = C_{GD} + C_{DS}$  is often used to analyze the dynamic switching procedure (cf. Section III).

Using  $V_1 = 200$  V from a dc power source, the measured transient drain-source voltages and gate-source voltages of  $Q_4$  and leakage inductance currents are shown in Fig. 4. The key experimental parameters of the DAB setup are listed in Table I. In Fig. 4, there are 8 groups of  $V_{DS,Q4}$  and  $V_{GS,Q4}$  corresponding to the phase shift  $\varphi$  varying from  $3^\circ$  to  $10^\circ$ . The

used power device  $Q_4$  is Infineon IPW65R080CFD, and the threshold voltage  $V_{GS(th)} = 4$  V can be read from the datasheet or manually measured. During the interval  $t \in [0.2 \mu s, 0.6 \mu s]$ ,  $V_{DS,Q4}$  decreases from  $V_1$  to 0 due to the discharge of output capacitance  $C_{oss,Q4}$ . In the meantime,  $V_{GS,Q4}$  gradually increases and when it reaches  $V_{GS(th)}$ , the transistor is turned on. Hence, if the drain-source voltage has been reduced to zero or near-zero at this instant, ZVS can be achieved. Otherwise, it transfers to hard switching if  $V_{DS,Q4}$  is still relatively high, and  $V_{GS,Q4}$  starts to oscillate. In conclusion, in order to realize zero voltage switching of  $Q_4$ , the output capacitance  $C_{oss,Q4}$  should be sufficiently discharged.

### III. IMPLEMENTATION OF NONLINEAR $C_{oss}$ - $V_{DS}$ PROFILE IN ZVS ANALYSIS

As concluded from the practical switching transients in the last section, the charges stored in the output capacitance should be fully released before turning on in order to achieve ZVS. Hence, in order to obtain an accurate ZVS range, firstly the stored charges should be properly calculated with varying  $V_{DS}$  and non-linear  $C_{oss}$ . Regarding this, the  $C_{oss}$  trajectory hardly varies with the temperature for Si super-junction [14], wide bandgap SiC [15] and GaN [16] devices, and thus the non-linear  $C_{oss}$ - $V_{DS}$  profile can be adopted to calculate the stored charges.

As shown in Fig. 2(b), the transient voltages  $V_{DS,Q2}$  and  $V_{DS,Q4}$  can be described by

$$\begin{cases} C_{oss,Q2} \frac{dV_{DS,Q2}}{dt} = -i_{D,Q2} \\ C_{oss,Q4} \frac{dV_{DS,Q4}}{dt} = i_{D,Q4} \end{cases} \quad (1)$$

where  $i_{D,Q2}$  and  $i_{D,Q4}$  are the drain currents of  $Q_2$  and  $Q_4$ , respectively. Combining (1) with the following relationship

$$\begin{cases} i_{D,Q4} + i_{D,Q2} = i_p \\ V_{DS,Q4} + V_{DS,Q2} = V_1 \end{cases} \quad (2)$$

leads to

$$i_p = [C_{oss,Q2} + C_{oss,Q4}] \frac{dV_{DS,Q4}}{dt} \quad (3)$$

For simplification, an equivalent capacitance  $C_{eq}$  defined as

$$C_{eq} = C_{oss}(V_1 - V_{DS,Q4}) + C_{oss}(V_{DS,Q4}) \quad (4)$$

is introduced to replace the term  $C_{oss,Q2} + C_{oss,Q4}$  in (3). The values of  $C_{oss}(V_1 - V_{DS,Q4})$  and  $C_{oss}(V_{DS,Q4})$  in (4) can be extracted from the nonlinear  $C_{oss}$ - $V_{DS}$  profile shown in Fig. 5(a), which is usually given in the datasheet. Therefore, the  $C_{eq}$  trajectory can be obtained as shown in Fig. 5(b).

The equivalent charge  $Q_{eq}$  stored in  $C_{eq}$  with an off-state drain-source voltage  $V_1$  can be calculated by

$$Q_{eq} = \int_0^{V_1} C_{eq} dV_{DS} \quad (5)$$

The patched area in Fig. 5(b) denotes the charge quantity with  $V_1 = 200$  V.

On the other hand, another condition for ZVS is that the stored charges  $Q_{eq}$  can be fully released into the leakage inductance current  $i_p$ , which means the conveyed charges in




Fig. 5. Nonlinear profiles of (a)  $C_{oss}$ , (b)  $C_{eq}$  along with  $V_{DS}$  for Infineon IPW65R080CFD.




Fig. 6. Measured leakage inductance currents  $i_p$  with  $\varphi = 3^\circ \sim 10^\circ$  and source-drain voltages  $V_{DS,Q4}$  with  $\varphi = 6^\circ, 10^\circ$  at the turn-on of  $Q_4$ . The lighter and darker patched areas are the conveyed charges  $Q_{ip}$  by  $i_p$  in the cases of  $\varphi = 6^\circ$  and  $\varphi = 10^\circ$ , respectively.




Fig. 7. Numerical integration (i.e. marked lines) of the measured currents  $i_p$  and the transient charge of  $C_{eq}$  (i.e. solid line) as the drain-source voltage of  $Q_4$  reversely changes from 0 V to 200 V.

$i_p$  should be larger than  $Q_{eq}$ . The total charges  $Q_{ip}$  in  $i_p$  at the turning on of  $Q_4$  could be represented by the patched areas in Fig. 6. Therein, the lighter patched area denotes  $Q_{ip}$  in the case of  $\varphi = 6^\circ$  and the darker is  $Q_{ip}$  in the case of  $\varphi = 10^\circ$ . It can be seen that the value of  $Q_{ip}$  decreases as  $\varphi$  is increased from  $3^\circ$  to  $10^\circ$ . For the convenience of analysis,  $t = 0.6 \mu s$  is deemed the time origin and  $t = 0.2 \mu s$  the transient ending. Therefore, the transient charge  $Q$  conveyed by  $i_p$  during change of  $V_{DS}$  can be calculated by using a numerical integration technique. Corresponding to different  $\varphi$ , the trajectories of  $Q$  are shown by different marked lines in Fig. 7. Note that  $Q$  is equal to the total charge  $Q_{ip}$  when  $V_{DS}$  reaches 200 V. As a comparison, the transient charge stored in the equivalent output capacitance  $C_{eq}$  is also shown in Fig. 7, denoted by the solid line with a final value of  $Q_{eq}$  (cf. Fig.

5(b)).

In the case of  $\varphi = 10^\circ$ , the available charge  $Q_{ip} = 0.4 \mu C$  in the current is lower than the stored charge  $Q_{eq} = 0.58 \mu C$  in the equivalent capacitance, indicating an insufficient discharge of  $C_{eq}$ . Hence,  $V_{DS,Q4}$  sharply drops from 115 V to 0 V in less than  $0.1 \mu s$  (cf. Fig. 4) and severe oscillations are induced in the leakage inductance current. This non-ZVS case should be avoided since it might increase the switching losses and even potentially break the power device [6] due to high  $dv/dt$ . In cases of  $\varphi = 3^\circ \dots 7^\circ$ , the charge  $Q_{ip}$  is larger than  $Q_{eq}$ , e.g.  $Q_{ip} = 0.67 \mu C$  with  $\varphi = 6^\circ$ . Therefore, the equivalent capacitance  $C_{eq}$  can be totally discharged before  $Q_4$  is turned on. In terms of the middle cases where  $\varphi = 8^\circ, 9^\circ$ , the transferred charge  $Q_{ip}$  (equals  $0.48 \mu C$  with  $\varphi = 9^\circ$ ) by the current is a bit lower than  $Q_{eq}$ , also implying an insufficient discharge of  $C_{eq}$ . One difference from the  $10^\circ$  case is that the drain-source voltage of  $Q_4$  has reduced to a sufficient low level at turning on, e.g. 45 V for  $\varphi = 9^\circ$  and even lower for  $\varphi = 8^\circ$  (cf. Fig. 4). Thus no obvious oscillations are stimulated and they are named as quasi-ZVS in Fig. 7. Due to that the switching losses are increased in quasi-ZVS cases (i.e.  $\varphi = 8^\circ, 9^\circ$ ) and the power devices could be impaired in non-ZVS cases (i.e.  $\varphi = 10^\circ$ ), the ZVS is regarded failed in the quasi-ZVS and non-ZVS cases.

#### IV. ZVS RANGE COMPARISON WITH EXPERIMENTAL VALIDATION

There are mainly three approaches to derive the ZVS range in literature, named as App1, App2 and App3 in the following, and the proposed ZVS range calculation method is represented by Pro..

**App1:** The most often used method [7] to calculate the ZVS conditions is by

$$I_3 = \frac{nV_2}{4\pi L f_{sw}} [(k-1)\alpha_p - 2\varphi] \geq 0 \rightarrow \alpha_p \geq \frac{2}{k-1}\varphi \quad (6)$$

where  $k = V_1/(nV_2)$  is the input/output dc voltage ratio and  $f_{sw}$  is the switching frequency.

**App2:** Another conventional method [9], [17] to calculate the ZVS conditions is focusing on the energy exchange, leading to

$$\alpha_p \geq \frac{2}{k-1}\varphi + \frac{4\pi L f_{sw}}{(k-1)nV_2} \sqrt{\frac{4nC V_1 V_2 - 2C V_1^2}{L}} \quad (7)$$

where  $C = 1/V_1 \int_0^{V_1} C_{oss} dV_{DS}$ . In this energy-based method, other than the missing consideration of the non-linearity of the output capacitance, the calculation is complex and it is difficult to achieve the same accuracy as the proposed method. This is because more converter components are involved in the derivation [17], and the calculation will become even more complex if the non-linear  $C_{oss}$  is considered.

**App3:** A third method in [10] is comparing the stored charges  $Q_{coss}$  in  $C_{oss,Q4}$  (i.e.  $Q_{coss} = \int_0^{V_1} C_{oss} dV_{DS}$ ) with

the two defined charges  $Q_A$  and  $Q_B$  as shown in Fig. 8(a), resulting in

$$\begin{cases} Q_A = -\int_{t_x}^{t_{xy}} i_p dt \geq Q_{coss} \\ Q_B = -\int_{t_{xy}}^{t_y} i_p dt \geq Q_{coss} \end{cases} \Rightarrow \alpha_p \geq \max. \left\{ \begin{aligned} &\frac{2}{k-1}\varphi + \frac{4\pi f_{sw}}{k-1} \sqrt{\frac{LQ_{eq}}{nV_2}}, \\ &\frac{2}{k-1}\varphi + \frac{4\pi f_{sw}}{k-1} \sqrt{\frac{(k-1)LQ_{eq}}{nV_2}} \end{aligned} \right\} \quad (8)$$

Although the non-linearity of the output capacitance is included in this method, the integration limits are not properly considered. As comparison, the integration limits of App3 and the proposed method are depicted in Fig. 8(b), represented by  $t_x, t_y$  and  $t_1, t_2$ , respectively. It can be seen from Fig. 8(b) that the discharging procedure of the output capacitance of  $Q_4$  is completed within  $[t_1, t_2]$ , which means that this procedure has not began at  $t = t_x$  and has finished at  $t = t_y$ . Therefore, the involved ranges of  $[t_x, t_1]$  and  $[t_2, t_y]$  in the calculation (cf. (8)) of the conveyed charges of  $i_p$  in App3 is not appropriate. As a result, although the calculated  $Q_A$  and  $Q_B$

$$\begin{cases} Q_A = 0.36 \mu C > Q_{coss} = 0.29 \mu C \\ Q_B = 0.44 \mu C > Q_{coss} = 0.29 \mu C \end{cases} \quad (9)$$

satisfy the ZVS conditions (8) in App3, the soft switching actually fails in the operating case of  $\varphi = 10^\circ$  as in shown Fig. 8(a).

**Pro.:** Based on the ZVS analysis in Section III, the proposed method of deriving ZVS condition is to compare the stored charges in the equivalent capacitance  $C_{eq}$  with the conveyed charges in current  $i_p$  during transients, i.e.

$$Q_{ip} = -\int_0^{T_{dead}} i_p dt \geq Q_{eq} = \int_0^{V_1} C_{eq} dV_{DS} \quad (10)$$

The time  $0 \rightarrow T_{dead}$  in (10) (cf. Fig. 8(b)) can be mapped to  $0.6 \mu s \rightarrow 0.2 \mu s$  in Fig. 6. For comparing with App3, the calculated  $Q_{ip}$  and  $Q_{eq}$  are

$$Q_{ip} = 0.4 \mu C < Q_{eq} = 0.58 \mu C \quad (11)$$

and it does not satisfy the ZVS condition (10) of the proposed method, which is consistent with the failed ZVS case in Fig. 8(b).

As discussed in Section III (cf. Fig. 7), the boundary ZVS case is at  $\varphi = 7^\circ$ . Seen from the practical  $i_p$  waveform in the case of  $\varphi = 7^\circ$  in Fig. 6, an approximate method to estimate  $Q_{ip}$  is by dividing the transient procedure into two intervals

$$i_p = \begin{cases} -I_3, & t \in [0, \frac{T_{dead}}{2}] \\ -I_3 + \frac{nV_2}{L} \left( t - \frac{T_{dead}}{2} \right), & t \in [\frac{T_{dead}}{2}, T_{dead}] \end{cases} \quad (12)$$

where  $0 \rightarrow T_{dead}/2$  corresponds to  $0.6 \mu s \rightarrow 0.4 \mu s$  in Fig. 6 and  $T_{dead}/2 \rightarrow T_{dead}$  is  $0.4 \mu s \rightarrow 0.2 \mu s$ . In other words, the value of  $i_p$  is approximated as constant  $-I_3$  in the first half of the dead time and a linear change in the second half. Hence, the ZVS limitation can be further derived by combining (10) and (12), resulting in

$$\alpha_p \geq \frac{2}{k-1}\varphi + \frac{4\pi L f_{sw}}{(k-1)nV_2} \left[ \frac{Q_{eq}}{T_{dead}} + \frac{nV_2}{8L} T_{dead} \right] \quad (13)$$




Fig. 8. (a) In the calculation method of App3, the defined two charges  $Q_A$  and  $Q_B$  in [10] with the case of  $\varphi = 10^\circ$ , corresponding to the integration ranges of  $[t_x, t_{xy}]$  and  $[t_{xy}, t_y]$ , respectively. (b) In the proposed method Pro., the defined  $Q_{ip}$  and relevant integration range  $[t_1, t_2]$ , which is also the dead time interval.

Note that the converter might operate in other working scenarios (e.g.  $Q_2$  turns off before  $Q_8$  turns on in Fig. 2(a)) with a different combination of the three control variables, and in that case, the calculation of the peak value of  $i_p$  will be changed accordingly, but the principle of the proposed ZVS range derivation remains the same.

Using the same parameters as in Fig. 4, the calculated ZVS ranges ( $\alpha_p - \varphi$  plane) of  $Q_4$  can be obtained with different approaches, as shown in Fig. 9. For practical validation, 24 experimental cases with different system configurations Config.1 ~ Config.3 are also depicted in the figure. The key parameters of the three configurations can be found in Table II. In Config.1, the value of  $\varphi$  is regulated from  $3^\circ$  to  $10^\circ$ , which is the same as Fig. 4, and the boundary is at  $\varphi_b = 7^\circ$  (cf. Fig. 7). Note that in order to distinguish the measured experimental ZVS boundary from the calculated results with different methods,  $\varphi_b$  is introduced in Table II to denote the practical ZVS boundary. Similarly, by varying  $\varphi$  between  $6^\circ \sim 13^\circ$  and  $9^\circ \sim 16^\circ$ , the measured ZVS boundaries are found at  $\varphi_b = 10^\circ$  and  $\varphi_b = 12^\circ$  for Config.2 and Config.3, respectively. As a comparison, the calculated ZVS boundaries using prior-art approaches App1 ~ App3 and the proposed method Pro. are shown in the last four columns of Table II. It can be seen that the calculated boundary  $\varphi$  with the proposed




Fig. 9. Calculated ZVS boundaries of  $Q_4$  using prior-art approaches App1, App2, App3 and the proposed method Pro., and experimental cases (denoted by marked points) with different system parameter configurations (cf. Table II) and the obtained experimental ZVS boundaries (i.e. Exp. border).

TABLE II  
MEASURED AND CALCULATED ZVS BOUNDARIES FOR DIFFERENT SYSTEM PARAMETER CONFIGURATIONS

Configs.	$V_1$	$V_2$	$\alpha_p$	$\alpha_s$	$\varphi_b$	App1	App2	App3	Pro.
Config.1	200 V	35 V	$60^\circ$	$110^\circ$	$7^\circ$	$19^\circ$	$13^\circ$	$11^\circ$	$6.4^\circ$
Config.2	200 V	35 V	$70^\circ$	$140^\circ$	$10^\circ$	$22.2^\circ$	$16.1^\circ$	$14.2^\circ$	$9.6^\circ$
Config.3	200 V	35 V	$80^\circ$	$160^\circ$	$12^\circ$	$25.3^\circ$	$19.3^\circ$	$17.4^\circ$	$12.8^\circ$
Config.4	200 V	45 V	$110^\circ$	$160^\circ$	$5^\circ$	$14.8^\circ$	$7.3^\circ$	$6^\circ$	$5^\circ$
Config.5	230 V	25 V	$40^\circ$	$150^\circ$	$16^\circ$	$32.6^\circ$	$23.2^\circ$	$17.6^\circ$	$15.4^\circ$
Config.6	170 V	25 V	$40^\circ$	$150^\circ$	$5^\circ$	$18.9^\circ$	$16.4^\circ$	$8.6^\circ$	$5.6^\circ$

method is more close to the measured  $\varphi_b$  than the other three approaches.

In order to further verify the accuracy of proposed method with different input/output dc voltages, Config.4 ~ Config.6 are implemented. In Config.4, the practical transient waveforms of  $V_{DS,Q4}$  and  $i_p$  are shown in top inset and middle inset of Fig. 10. Similar to Fig. 7, the numerical integration results are shown in the bottom inset of Fig. 10, from which the measured boundary  $\varphi_b = 5^\circ$  can be obtained. Applying the same procedure to Config.5 and Config.6, the measured and calculated ZVS boundaries are as listed in Table II. By comparing the measured boundary  $\varphi_b$  with the calculated values using different methods, the same conclusion can be achieved that the proposed method can predict a more accurate ZVS boundary than the other three methods.

## V. CONCLUSIONS

Based on the practical switching transient, an accurate ZVS range calculation method is presented by considering the non-linearity nature of output capacitance in a power device. The method considers both charge and discharge of the power devices in the same bridge leg. On this basis, the concepts of equivalent capacitance and equivalent charge are derived to analyze the ZVS transition and calculate the ZVS range. Compared to prior-art ZVS range calculation approaches where the non-linear output capacitance is not considered, the proposed






Fig. 10. Measured transients of  $V_{DS,Q4}$ ,  $i_p$  and numerical integration of measured  $i_p$  for Config.4 in the top inset, middle inset and bottom inset, respectively.

method has a higher accuracy. Although more calculations are needed, this is worthy to use as it is vital in practice to accurately forecast the ZVS boundary. Multiple experiments with different system parameters are implemented and the results are in agreement with the theoretical prediction.

## REFERENCES

- [1] R. D. Doncker, D. Divan, and M. Kheraluwala, "A three-phase soft-switched high power density DC/DC converter for high power applications," in *Conference Record of the 1988 IEEE Industry Applications Society Annual Meeting*, IEEE, 1988.
- [2] F. Blaabjerg, Y. Yang, D. Yang, and X. Wang, "Distributed power-generation systems and protection," *Proceedings of the IEEE*, vol. 105, no. 7, pp. 1311–1331, 2017.
- [3] N. M. L. Tan, T. Abe, and H. Akagi, "Design and performance of a bidirectional isolated DC-DC converter for a battery energy storage system," *IEEE Trans. Power Electron.*, vol. 27, no. 3, pp. 1237–1248, Mar. 2012.
- [4] F. Krismer and J. W. Kolar, "Efficiency-optimized high-current dual active bridge converter for automotive applications," *IEEE Trans. Ind. Electron.*, vol. 59, no. 7, pp. 2745–2760, Jul. 2012.

- [5] H. Chung, S. Y. R. Hui, and K. K. Tse, "Reduction of power converter EMI emission using soft-switching technique," *IEEE Trans. Electromagn. Compat.*, vol. 40, no. 3, pp. 282–287, Aug. 1998.
- [6] R. Li, Q. Zhu, and M. Xie, "A new analytical model for predicting  $dv/dt$ -induced low-side MOSFET false turn-on in synchronous buck converters," *IEEE Trans. Power Electron.*, vol. 34, no. 6, pp. 5500–5512, Jun. 2019.
- [7] G. Oggier, G. O. García, and A. R. Oliva, "Modulation strategy to operate the dual active bridge DC-dc converter under soft switching in the whole operating range," *IEEE Trans. Power Electron.*, vol. 26, no. 4, pp. 1228–1236, Apr. 2011.
- [8] S. S. Shah, V. M. Iyer, and S. Bhattacharya, "Exact solution of ZVS boundaries and AC-port currents in dual active bridge type DC-dc converters," *IEEE Trans. Power Electron.*, vol. 34, no. 6, pp. 5043–5047, Jun. 2019.
- [9] A. Rodríguez, A. Vázquez, D. G. Lamar, M. M. Hernando, and J. Sebastián, "Different purpose design strategies and techniques to improve the performance of a dual active bridge with phase-shift control," *IEEE Trans. Power Electron.*, vol. 30, no. 2, pp. 790–804, Feb. 2015.
- [10] J. Everts, "Closed-form solution for efficient ZVS modulation of DAB converters," *IEEE Trans. Power Electron.*, vol. 32, no. 10, pp. 7561–7576, Oct. 2017.
- [11] F. Krismer and J. W. Kolar, "Closed form solution for minimum conduction loss modulation of DAB converters," *IEEE Trans. Power Electron.*, vol. 27, no. 1, pp. 174–188, Jan. 2012.
- [12] D. Segaran, D. G. Holmes, and B. P. McGrath, "Enhanced load step response for a bidirectional DC-dc converter," *IEEE Trans. Power Electron.*, vol. 28, no. 1, pp. 371–379, 2013.
- [13] B. Zhao, Q. Song, W. Liu, and Y. Sun, "Dead-time effect of the high-frequency isolated bidirectional full-bridge DC-dc converter: Comprehensive theoretical analysis and experimental verification," *IEEE Trans. Power Electron.*, vol. 29, no. 4, pp. 1667–1680, 2014.
- [14] *Power mosfet electrical characteristics*, TOSHIBA, Jul. 2018.
- [15] Z. Chen, D. Boroyevich, R. Burgos, and F. Wang, "Characterization and modeling of 1.2 kv, 20 A SiC mosfets," in *Proc. IEEE Energy Conversion Congress and Exposition*, Sep. 2009, pp. 1480–1487.
- [16] G. Zulauf, S. Park, W. Liang, K. N. Surakitbovorn, and J. Rivas-Davila, "Coss losses in 600 V GaN power semiconductors in soft-switched, high- and very-high-frequency power converters," *IEEE Trans. Power Electron.*, vol. 33, no. 12, pp. 10748–10763, Dec. 2018.
- [17] Z. Shen, R. Burgos, D. Boroyevich, and F. Wang, "Soft-switching capability analysis of a dual active bridge dc-dc converter," in *Proc. IEEE Electric Ship Technologies Symp.*, Apr. 2009, pp. 334–339.